

Flammable battery storage enclosure 20 gallon capacity

(A) Storage in excess of 25 gallons of flammable liquids or 60 gallons of liquids with a flashpoint greater than 199.4 o F (93 o C) (formerly designated Class IIIB Combustible liquids) shall be ...